



INSTALATION MANUAL

AE Solar GmbH

Messerschmittring 54
86343 Königsbrunn
Germany

Tel.: +49 8231 92 92 52 2
Fax: +49 8231 97 82 68 9
Email: sales@ae-solar.com
Web: www.ae-solar.com

1. General Information

1.1 Overview

Thanks for choosing AE SOLAR PV modules. In order to ensure the PV modules are installed correctly, please read the following installation instructions carefully before modules are installed and used. Please remember that these products generate electricity and certain safety measures need to be taken to avoid danger.

Make sure the module array is designed in such a way not to exceed the maximum system voltage of any system component such as connectors or inverters and only use compatible connectors of the same type.

The assembly is to be mounted over a fire resistant roof covering rated for the application. Before mounting the module, please consult your local building department to determine approved roofing materials.


The modules are qualified for Class II: which can be used in systems operating at 50 V DC or >240W.

Where general contact access is anticipated; When the modules are for rooftop application, it is necessary to take the overall fire rating of the finished structure as well as operation and maintenance into account. The roofing PV system shall be installed after being evaluated by construction experts or engineers and with official analysis results for the entire structure. It shall be proved capable of supporting extra system bracked pressure, including PV module weight.


1.2 Warnings



- ❑ PV modules generate DC electrical energy when exposed to sunlight or other light sources. Active parts of module such as terminals can result in burns, sparks, and lethal shock.
- ❑ Artificially concentrated sunlight shall not be directed on the module or panel.
- ❑ Front protective glass is utilized on the module. Broken solar module glass is an electrical safety hazard (may cause electric shock or fire). These modules cannot be repaired and should be replaced immediately.
- ❑ To reduce the risk of electrical shocks or burns, modules may be covered with an opaque material during installation to avoid injury.
- ❑ The installation work of the PV array can only be done under the protection of sun-sheltering covers or sunshades and only qualified person can install or perform maintenance work on this module.
- ❑ Follow the battery manufacture's recommendations if batteries are used with modules.
- ❑ Do not use this module to replace or partly replace roofs and walls of living buildings.
- ❑ Do not install modules where flammable gas may be present.
- ❑ Do not remove any part installed by AE Solar or disassemble the module.



- All instructions should be read and understood before attempting to install, wire, operate and maintain the module.
- Don't lift up PV modules using the attached cables or the junction box.
- Do not touch live terminals with bare hands. Use insulated tools for electrical connections.



- All PV systems must be grounded to earth. If there is no special regulation, please follow the National Electrical Code or other national code.
- Under normal conditions, a photovoltaic module is likely to experience conditions that produce more current and/or voltage than reported at standard test conditions. Accordingly, the value of I_{sc} and V_{oc} marked on the module should be multiplied by 1.25 when determining PV system component voltage ratings, conductor current ratings, fuse sizes, and size of controls connected to the PV output.
- Once the PV module has been shipped to the installation site, all of the parts should be unpacked properly with care.
- Only the modules with the same type and the capacity should be connected in series inside the string.
- During transporting modules, please attempt to minimize shock or vibration to the module, as this may damage the module or lead to cell micro cracks.
- During all transportation situations, never drop the module from a vehicle, house or hands. This will damage module.
- Do not clean the glass with chemicals. Only use tap water. Make sure the module surface temperature is cool to the touch. Cleaning modules with cool water when module surface temp is high may result in glass breakage.
- Do not stand or step on the PV module like below pictures show. This is prohibited and there is a risk of damage to the module and cause injury for you.



- ❑ Do not disconnect modules from the circuit, when they are operating in the system and deriving electrical load.
- ❑ When looking at PV modules with anti-reflection (AR) coating technology, it will be normal to see some cells with a slight color difference at different angles. Modules with LRF(light reflective film) and without LRF should not be built in the same array or roof.
- ❑ Connector of junction box can not be contacted with oily substances, for example, lubricant, rust inhibitor etc.
- ❑ The maximum altitude the PV module is designed for $\leq 2000\text{m}$.
- ❑ Do not carry a module on your head, with the backsheet facing towards to your helmet, if it is not avoidable, please make sure that, the module is facing with the glass side to your helmet.
- ❑ The maximum irradiance is 1300W/m^2 for module with transparent and white backsheet rear.
- ❑ Meaning of crossed –out wheeled dustbin:
Do not dispose of electrical appliances as unsorted municipal waste, use separate collection facilities.
Contact your local government for information regarding the collection systems available.
If electrical appliances are disposed of in landfills or dumps, hazardous substances can leak into the groundwater and get into the food chain, damaging your health and well-being.
When replacing old appliances with new ones, the retailer is legally obligated to take back your old appliance for disposals at least free of charge.



2. Installation

2.1 Installation Safety

- ❑ Always wear protective head gear, insulating gloves and safety shoes (with rubber soles).
- ❑ Keep the PV module packed in the carton until installation.
- ❑ Do not touch the PV module unnecessarily during installation. The glass surface and the frame may be hot. There is a risk of burns and electric shock.
- ❑ Do not work in rain, snow or windy conditions.
- ❑ Due to the risk of electrical shock, do not perform any work if the terminals of the PV module are wet.
- ❑ Use insulated tools and do not use wet tools.
- ❑ When installing PV modules, do not drop any objects (e.g., PV modules or tools).
- ❑ Make sure flammable gasses are not generated or present near the installation site.
- ❑ Insert module connectors fully and correctly. An audible "click" sound should be heard. This sounds confirms the connectors are fully seated. Check all connections.
- ❑ The module leads should be securely fastened to the module frame, Wire Management should be

done in a way to avoid the connector from scratching or impacting the back sheet of the module.

- Do not touch the junction box and the end of the interconnect cables (connectors) with bare hands during installation or under sunlight, regardless if the PV module is connected to or disconnected from the system.
- Do not expose the PV module to excessive loads on the surface of the PV module or twist the frame.
- Do not hit or put excessive load on the glass or back sheet, this may break the cells or cause micro cracks.
- During the installation or operation, don't use sharp tools to wipe the back sheet and glass. Scratches can appear on the module.
- Do not drill holes in the frame. It may cause corrosion of the frame.
- When installing modules on roof mounted structures, please try to follow the "from top to bottom" and/or "from left to right" principle, and don't step on the module. This will damage the module and would be dangerous for personal safety fire tested according ANSI-UL-790:2004.

2.2 Installation Condition

2.2.1 Climate Condition

Please install the modules in the following conditions:

- a) Operating temperature: within -40°C (-40°F) to 85°C (185°F)
- b) Humidity: $< 85\text{RH}\%$

* Note: The mechanical load bearing (include wind and snow loads) of the module is based on the approved mounting methods. The professional system installer must be responsible for mechanical load calculation according to the system design.

2.2.2 Site Selection

In most applications, AE Solar solar PV modules should be installed in a location where they will receive maximum sunlight throughout the year. In the Northern Hemisphere, the module should typically face south, and in the Southern Hemisphere, the modules should typically face north. Modules facing 30 degrees away from true South (or North) will lose approximately 10 to 15 percent of their power output. If the module faces 60 degrees away from true South (or North), the power loss will be 20 to 30 percent. When choosing a site, avoid trees, buildings or obstructions, which could cast shadows on the solar photovoltaic modules especially during the winter months when the arc of the sun is lowest over the horizon. Shading causes loss of output, even though the factory fitted bypass diodes of the PV module will minimize any such loss.

Do not install the PV module near open flame or flammable materials.

When solar modules are used to charge batteries, the battery must be installed in a manner, which will protect the performance of the system and the safety of its users. Follow the battery manufacturer's


guidelines concerning installation, operation and maintenance recommendations. In general, the battery (or battery bank) should be away from the main flow of people and animal traffic. Select a battery site that is protected from sunlight, rain, snow, debris, and is well ventilated. Most batteries generate hydrogen gas when charging, which can be explosive. Do not light matches or create sparks near the battery bank. When a battery is installed outdoors, it should be placed in an insulated and ventilated battery case specifically designed for the purpose.

Do not install the PV module in a location where it would be immersed in water or continually exposed to water from a sprinkler or fountain etc.

2.2.3 Tilt Angle Selection

The tilt angle of the PV module is measured between the surface of the PV module and a horizontal ground surface (Figure 1). The PV module generates maximum output power when it faces the sun directly.

For standalone systems with batteries where the PV modules are attached to a permanent structure, the tilt angle of the PV modules should be selected to optimize the performance based on seasonal load and sunlight. In general, if the PV output is adequate when irradiance is low (e.g., winter), then the angle chosen should be adequate during the rest of the year. For grid-connected installations where the PV modules are attached to a permanent structure, PV modules should be tilted so that the energy production from the PV modules will be maximized on an annual basis.



2.3 Mechanical Installation Introduction

Solar PV modules usually can be mounted by using the following methods: bolts and clamps.

* Note:

- 1) All installation methods herein are only for reference, and AE solar will not provide related mounting components, the system installer or trained professional personnel must be responsible for the PV system's design, installation, and mechanical load calculation and security of the system.
- 2) Before installation, the following items should be addressed:
 - a) Visually check the module for any damage. Clean the module if any dirt or residue remains from shipping .
 - b) Check if module serial number stickers match.
- 3) AE Solar modules are designed to meet a maximum positive (or downward) pressure of 1600Pa (Only


referring to the mentioned module type in this manual) and negative (or upward) pressure of 1600Pa. This design load was then tested with a safety factor of 1.5 times. AE Solar modules are tested under a maximum downward pressure of 2400Pa and upward pressure of 2400Pa. When mounting modules in snow-prone or high-wind environments, special care should be taken to mount the modules in a manner that provides sufficient design strength while meeting local code requirements. Please take in note, that the limitation of Tilt angle / slope is maximum 60 °.

According to IEC 61215, solar modules are rated as a class C Flame-Spread Ratings product according to NSF/ANSI 342 standards


2.3.1 Mounting with Bolts

For mounting with bolts, the following modules in tables 1 are applicable.

The frame of each module has 8 mounting holes (Length* Width: 14mm*9mm) used to secure the modules to support structure. Always use all the eight mounting holes to secure the modules. The module frame must be attached to a mounting rail using M8 corrosion-proof bolts together with spring washers and flat washers in eight symmetrical locations on the PV module. The applied torque value should be big enough to fix the modules steadily. The reference value for M8 bolt is 16~20N*m. As to special support system or special installation requirement, please reconfirm with the support's supplier for the torque value. Please find detailed mounting information in the below illustration as Figure 2&3&4.



2.3.1.1 Mounting with Bolts (eight mounting holes)



PV module installed with bolt fitting method (eight mounting holes)

Module type		Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load	Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load Note: The installation method is based on the internal results in AE Solar
		Module dimensions(mm) A*B	
60 cells	P	Height of the frame (mm)	35
		AE265P6-60	1650*992
		AE270P6-60	1650*992
		AE275P6-60	1650*992
		AE280P6-60	1650*992
		AE285P6-60	1650*992
		AE285P6-60	1650*992
		AE290P6-60	1650*992
		AE280M6-60	1650*992
	M	AE285M6-60	1650*992
		AE290M6-60	1650*992
		AE295M6-60	1650*992
		AE300M6-60	1650*992
		AE305M6-60	1650*992
		AE310M6-60	1650*992
		AE315M6-60	1650*992
		AE320M6-60	1650*992
72 cells	P	Height of the frame (mm)	40
		AE315P6-72	1956*992
		AE320P6-72	1956*992
		AE325P6-72	1956*992
		AE330P6-72	1956*992
		AE335P6-72	1956*992
		AE340P6-72	1956*992
	M	AE340M6-72	1956*992
		AE345M6-72	1956*992
		AE350M6-72	1956*992
		AE355M6-72	1956*992
		AE360M6-72	1956*992
		AE365M6-72	1956*992
		AE370M6-72	1956*992
		AE375M6-72	1956*992
		AE380M6-72	1956*992
		AE385M6-72	1956*992

Module type		Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load	Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load Note: The installation method is based on the internal results in AE Solar
		Module dimensions(mm) A*B	
		Height of the frame(mm)	35
60 cells	M	AE HM305M6-60	1665*1002
		AE HM310M6-60	1665*1002
		AE HM315M6-60	1665*1002
		AE HM320M6-60	1665*1002
		AE HM325M6-60	1665*1002
		AE HM330M6-60	1665*1002
		AE HM335M6-60	1665*1002
		Height of the frame(mm)	40
72 cells	M	AE HM370M6-72	1979*1002
		AE HM375M6-72	1979*1002
		AE HM380M6-72	1979*1002
		AE HM385M6-72	1979*1002
		AE HM390M6-72	1979*1002
		AE HM395M6-72	1979*1002
		AE HM400M6-72	1979*1002

Table 1: Mechanical dimensions for bolt fitting method (eight mounting holes)

Notes: Group 1~48 refer to appendix 1 for details.

According to IEC 61215 for a maximum positive design loading of below 1600Pa, and negative design loading 1600Pa, with 1.5 times safety factor.

2.3.1.2 Mounting with Bolts (four mounting holes)




Figure 3: PV module installed with bolt fitting method (four mounting holes)


Module type			Max. Design Pressure: 3600Pa (positive) &1600Pa (negative) mechanical load	Max. Design Pressure: 3600Pa (positive) &1600Pa (negative) mechanical load Note: The installation method is based on the internal results in AE Solar
			Module dimensions(mm) A*B	
60 cells	P	Height of the frame(mm)	35	
		AE265P6-60	1650*992	
		AE270P6-60	1650*992	
		AE275P6-60	1650*992	
		AE280P6-60	1650*992	
		AE285P6-60	1650*992	
		AE285P6-60	1650*992	
		AE290P6-60	1650*992	
	M	AE280M6-60	1650*992	
		AE285M6-60	1650*992	
		AE290M6-60	1650*992	
		AE295M6-60	1650*992	

60 cells	M	AE300M6-60	1650*992
		AE305M6-60	1650*992
		AE310M6-60	1650*992
		AE315M6-60	1650*992
		AE320M6-60	1650*992
72 cells	P	Height of the frame(mm)	40
		AE315P6-72	1956*992
		AE320P6-72	1956*992
		AE325P6-72	1956*992
		AE330P6-72	1956*992
		AE335P6-72	1956*992
		AE340P6-72	1956*992
	M	AE340M6-72	1956*992
		AE345M6-72	1956*992
		AE350M6-72	1956*992
		AE355M6-72	1956*992
		AE360M6-72	1956*992
		AE365M6-72	1956*992
		AE370M6-72	1956*992
		AE375M6-72	1956*992
		AE380M6-72	1956*992
		AE385M6-72	1956*992
		Height of the frame(mm)	35
60 cells	M	AE HM305M6-60	1665*1002
		AE HM310M6-60	1665*1002
		AE HM315M6-60	1665*1002
		AE HM320M6-60	1665*1002
		AE HM325M6-60	1665*1002
		AE HM330M6-60	1665*1002
		AE HM335M6-60	1665*1002
		Height of the frame(mm)	40
72 cells	M	AE HM370M6-72	1979*1002
		AE HM375M6-72	1979*1002
		AE HM380M6-72	1979*1002
		AE HM385M6-72	1979*1002
		AE HM390M6-72	1979*1002
		AE HM395M6-72	1979*1002
		AE HM400M6-72	1979*1002

Note: The installation method of bolt fitting (four mounting holes) is based on the internal results in AE Solar. According to IEC 61215 for a maximum positive design loading of below 1600Pa, and negative design loading 1600Pa, with 1.5 times safety factor.

2.3.1.3 Mounting with Bolts (Nextracker four mounting holes)

Figure 4: PV module installed with bolt fitting method (NEX)



Module type		Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load	Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load Note: The installation method is based on the internal results in AE Solar
		Module dimensions(mm) A*B	
60 cells	P	Height of the frame (mm)	35
		AE265P6-60	1650*992
		AE270P6-60	1650*992
		AE275P6-60	1650*992
		AE280P6-60	1650*992
		AE285P6-60	1650*992
		AE285P6-60	1650*992
		AE290P6-60	1650*992
		AE280M6-60	1650*992
	M	AE285M6-60	1650*992
		AE290M6-60	1650*992
		AE295M6-60	1650*992
		AE300M6-60	1650*992
		AE305M6-60	1650*992
		AE310M6-60	1650*992
		AE315M6-60	1650*992
		AE320M6-60	1650*992
72 cells	P	Height of the frame (mm)	40
		AE315P6-72	1956*992
		AE320P6-72	1956*992
		AE325P6-72	1956*992
		AE330P6-72	1956*992
		AE335P6-72	1956*992
		AE340P6-72	1956*992
	M	AE340M6-72	1956*992
		AE345M6-72	1956*992
		AE350M6-72	1956*992
		AE355M6-72	1956*992
		AE360M6-72	1956*992
		AE365M6-72	1956*992
		AE370M6-72	1956*992
		AE375M6-72	1956*992
		AE380M6-72	1956*992
		AE385M6-72	1956*992

Module type		Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load	Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load Note: The installation method is based on the internal results in AE Solar
		Module dimensions(mm) A*B	
		Height of the frame (mm)	35
60 cells	M	AE HM305M6-60	1665*1002
		AE HM310M6-60	1665*1002
		AE HM315M6-60	1665*1002
		AE HM320M6-60	1665*1002
		AE HM325M6-60	1665*1002
		AE HM330M6-60	1665*1002
		AE HM335M6-60	1665*1002
		Height of the frame (mm)	40
72 cells	M	AE HM370M6-72	1979*1002
		AE HM375M6-72	1979*1002
		AE HM380M6-72	1979*1002
		AE HM385M6-72	1979*1002
		AE HM390M6-72	1979*1002
		AE HM395M6-72	1979*1002
		AE HM400M6-72	1979*1002



Note: The installation method of bolt fitting (NEX) is based on the experimental results in AE Solar According to IEC 61215 for a maximum positive design loading of below 1067Pa, and negative design loading 1067Pa, with 1.5 times safety factor.

2.3.2 Mounting with clamps

The module clamps should not come into contact with the front glass and must not deform the frame. Be sure to avoid shadowing effects from the module clamps. The module frame is not to be modified under any circumstances. When choosing this type of clamp-mounting method, please be sure to use at least four clamps on each module, two clamps should be attached on each long sides of the module. Depending on the local wind and snow loads, if excessive pressure load is expected, additional clamps or support would be required to ensure the module can bear the load. The applied torque value should be big enough to fix the modules steadily (Please consult with the clamp or support's supplier for the specific torque value). Please find detailed mounting information in the below illustration, the mounting place distance is suggested bigger than J and less than K. The installation diagram of clamp is shown in figure 5.

Note: The Movement of the mounting rail and the clamps center line are recommended to be within the black arrow area.

The min length of clamps is 50mm.






Figure 5: PV module installed at the side with Clamp fitting method

When installing modules using clamps on the long side of the frame, the applicable product types and installation locations are shown in figure 6 and table 4.

When installing modules using clamps on the short side of the frame, the applicable product types and installation locations are shown in figure 7 and table 5.

When installing modules using clamps on the long side & short side of the frame, the applicable product types and installation locations are shown in figure 8 and table 6.

When installing modules using clamps on the long side of the frame, the applicable product types and installation locations (The without C transparent backsheet series module) are shown in figure 9 and table 7.

2.3.2.1 Clamp Mounting on Long Sides of the Frames




Figure 6: Installation of clamps on long side of frames

Module type		Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load		
		Module dimensions(mm) A*B	J	K
60 cells	P	Height of the frame (mm)	35	
		AE265P6-60	1650*992	280
		AE270P6-60	1650*992	280
		AE275P6-60	1650*992	280
		AE280P6-60	1650*992	280
		AE285P6-60	1650*992	280
		AE285P6-60	1650*992	280
		AE290P6-60	1650*992	280
		AE280M6-60	1650*992	280
	M	AE285M6-60	1650*992	280
		AE290M6-60	1650*992	280
		AE295M6-60	1650*992	280
		AE300M6-60	1650*992	280
		AE305M6-60	1650*992	280
		AE310M6-60	1650*992	280
		AE315M6-60	1650*992	280
		AE320M6-60	1650*992	280
72 cells	P	Height of the frame (mm)	40	
		AE315P6-72	1956*992	280
		AE320P6-72	1956*992	280
		AE325P6-72	1956*992	280
		AE330P6-72	1956*992	280
		AE335P6-72	1956*992	280
		AE340P6-72	1956*992	280
	M	AE340M6-72	1956*992	280
		AE345M6-72	1956*992	280
		AE350M6-72	1956*992	280
		AE355M6-72	1956*992	280
		AE360M6-72	1956*992	280
		AE365M6-72	1956*992	280
		AE370M6-72	1956*992	280
		AE375M6-72	1956*992	280
		AE380M6-72	1956*992	280
		AE385M6-72	1956*992	280

Module type		Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load	Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load Note: The installation method is based on the internal results in AE Solar		
		Module dimensions(mm) A*B	J	K	
		Height of the frame(mm)	35		
60 cells	M	AE HM305M6-60	1665*1002	280	420
		AE HM310M6-60	1665*1002	280	420
		AE HM315M6-60	1665*1002	280	420
		AE HM320M6-60	1665*1002	280	420
		AE HM325M6-60	1665*1002	280	420
		AE HM330M6-60	1665*1002	280	420
		AE HM335M6-60	1665*1002	280	420
		Height of the frame(mm)	40		
72 cells	M	AE HM370M6-72	1979*1002	280	420
		AE HM375M6-72	1979*1002	280	420
		AE HM380M6-72	1979*1002	280	420
		AE HM385M6-72	1979*1002	280	420
		AE HM390M6-72	1979*1002	280	420
		AE HM395M6-72	1979*1002	280	420
		AE HM400M6-72	1979*1002	280	420

According to IEC 61215 for a maximum positive design loading of below 1600Pa, and negative design loading 1600Pa, with 1.5 times safety factor.

2.3.2.2 Clamp Mounting on Short Sides of the Frames





Figure 7: Installation of clamps on short side of frames

Module type			Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load		
			Module dimensions(mm) A*B	J	K
60 cells	P	Height of the frame(mm)	35		
		AE265P6-60	1650*992	50	240
		AE270P6-60	1650*992	50	240
		AE275P6-60	1650*992	50	240
		AE280P6-60	1650*992	50	240
		AE285P6-60	1650*992	50	240
		AE285P6-60	1650*992	50	240
		AE290P6-60	1650*992	50	240
		AE280M6-60	1650*992	50	240
	M	AE285M6-60	1650*992	50	240
		AE290M6-60	1650*992	50	240
		AE295M6-60	1650*992	50	240
		AE300M6-60	1650*992	50	240
		AE305M6-60	1650*992	50	240
		AE310M6-60	1650*992	50	240
		AE315M6-60	1650*992	50	240
		AE320M6-60	1650*992	50	240

72 cells	P	Height of the frame(mm)	40			
		AE315P6-72	1956*992	50	240	
		AE320P6-72	1956*992	50	240	
		AE325P6-72	1956*992	50	240	
		AE330P6-72	1956*992	50	240	
		AE335P6-72	1956*992	50	240	
		AE340P6-72	1956*992	50	240	
	M	AE340M6-72	1956*992	50	240	
		AE345M6-72	1956*992	50	240	
		AE350M6-72	1956*992	50	240	
		AE355M6-72	1956*992	50	240	
		AE360M6-72	1956*992	50	240	
		AE365M6-72	1956*992	50	240	
		AE370M6-72	1956*992	50	240	
		AE375M6-72	1956*992	50	240	
		AE380M6-72	1956*992	50	240	
		AE385M6-72	1956*992	50	240	
		Module type		Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load	Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load Note： The installation method is based on the internal results in AE Solar	
				Module dimensions(mm) A*B	J	K
		Height of the frame(mm)	35			
60 cells	M	AE HM305M6-60	1665*1002	50	240	
		AE HM310M6-60	1665*1002	50	240	
		AE HM315M6-60	1665*1002	50	240	
		AE HM320M6-60	1665*1002	50	240	
		AE HM325M6-60	1665*1002	50	240	
		AE HM330M6-60	1665*1002	50	240	
		AE HM335M6-60	1665*1002	50	240	
		Height of the frame(mm)	40			
72 cells	M	AE HM370M6-72	1979*1002	50	240	
		AE HM375M6-72	1979*1002	50	240	
		AE HM380M6-72	1979*1002	50	240	
		AE HM385M6-72	1979*1002	50	240	
		AE HM390M6-72	1979*1002	50	240	
		AE HM395M6-72	1979*1002	50	240	
		AE HM400M6-72	1979*1002	50	240	

Note: The installation method of clamps on short sides is based on the internal results in AE Solar.
According to IEC 61215 for a maximum positive design loading of below 1067Pa, and negative design loading 1067Pa, with 1.5 times safety factor.

2.3.2.3 Clamp Mounting on Long & Short Sides




Module type			Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load				
			Module dimensions(mm) A*B	J	K	M	N
60 cells	P	Height of the frame (mm)	35				
		AE265P6-60	1650*992	50	240	280	420
		AE270P6-60	1650*992	50	240	280	420
		AE275P6-60	1650*992	50	240	280	420
		AE280P6-60	1650*992	50	240	280	420
		AE285P6-60	1650*992	50	240	280	420
		AE285P6-60	1650*992	50	240	280	420
		AE290P6-60	1650*992	50	240	280	420
		AE280M6-60	1650*992	50	240	280	420
	M	AE285M6-60	1650*992	50	240	280	420
		AE290M6-60	1650*992	50	240	280	420
		AE295M6-60	1650*992	50	240	280	420
		AE300M6-60	1650*992	50	240	280	420
		AE305M6-60	1650*992	50	240	280	420
		AE310M6-60	1650*992	50	240	280	420
		AE315M6-60	1650*992	50	240	280	420
		AE320M6-60	1650*992	50	240	280	420
72 cells	P	Height of the frame (mm)	40				
		AE315P6-72	1956*992	50	240	280	480
		AE320P6-72	1956*992	50	240	280	480
		AE325P6-72	1956*992	50	240	280	480
		AE330P6-72	1956*992	50	240	280	480
		AE335P6-72	1956*992	50	240	280	480
		AE340P6-72	1956*992	50	240	280	480
		AE340M6-72	1956*992	50	240	280	480
	M	AE345M6-72	1956*992	50	240	280	480
		AE350M6-72	1956*992	50	240	280	480
		AE355M6-72	1956*992	50	240	280	480
		AE360M6-72	1956*992	50	240	280	480
		AE365M6-72	1956*992	50	240	280	480
		AE370M6-72	1956*992	50	240	280	480
		AE375M6-72	1956*992	50	240	280	480
		AE380M6-72	1956*992	50	240	280	480
		AE385M6-72	1956*992	50	240	280	480

Module type		Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load	Max. Design Pressure: 1600Pa (positive) &1600Pa (negative) mechanical load Note: The installation method is based on the internal results in AE Solar				
		Module dimensions(mm) A*B	J	K	M	N	
		Height of the frame(mm)	35				
60 cells	M	AE HM305M6-60	1665*1002	50	240	280	420
		AE HM310M6-60	1665*1002	50	240	280	420
		AE HM315M6-60	1665*1002	50	240	280	420
		AE HM320M6-60	1665*1002	50	240	280	420
		AE HM325M6-60	1665*1002	50	240	280	420
		AE HM330M6-60	1665*1002	50	240	280	420
		AE HM335M6-60	1665*1002	50	240	280	420
		Height of the frame(mm)	40				
72 cells	M	AE HM370M6-72	1979*1002	50	240	280	480
		AE HM375M6-72	1979*1002	50	240	280	480
		AE HM380M6-72	1979*1002	50	240	280	480
		AE HM385M6-72	1979*1002	50	240	280	480
		AE HM390M6-72	1979*1002	50	240	280	480
		AE HM395M6-72	1979*1002	50	240	280	480
		AE HM400M6-72	1979*1002	50	240	280	480


3. Wiring and Connection

- a) Before this procedure, please read the operation instructions of the PV system carefully. Make wiring by Multi-connecting cables between the PV modules in series or parallel connection, which is determined by user's configuration requirement for system power, current and voltage.
- b) PV modules connected in series should have similar connectors of identical type current, and modules must not be connected together to create a voltage higher than the permitted system voltage. The maximum number of modules in series depends on system design, the type of inverter used and environmental conditions.
- c) The maximum fuse rating value in an array string can be found on the product label or in the product datasheet. The fuse rating value is also corresponding to the maximum reverse current that a module can withstand, i.e. when one string is in shade then the other parallel strings of modules will be loaded by the shaded string and the current will pass through to create a current circuit. Based on the maximum series fuse rating of module and local electrical codes and standards, make sure the modules strings in parallel are protected with the appropriate in-line string fusing.
- d) Open the combiner box of the control system and connect the conductor from the PV arrays to the combiner box in accordance with the design and local codes and standards. The cross-sectional area and cable connector capacity must satisfy the maximum short-circuit of the PV system (for a single component, we recommended that the cross-sectional area of cables current will be 4mm^2 and the rated current of connectors be more than 10A), otherwise cables and connectors will become overheating for large current. Please pay attention to the temperature limit of cables is 85°C .
- e) All module frames and mounting racks must be properly equipotentially bonded in accordance with module frame using the local and national electrical codes. Attach the equipment equipotential bonded conductor to the hole and hardware provided. Note that a stainless steel star washer is used between the ground wire and module frame (see Figure 10 below). This washer is used to avoid corrosion due to dissimilar metals. Tighten the screw securely.



Equipotential bonding installation of PV modules

When modules are in series connection, the string voltage is sum of every individual module in one string.
 When modules are in parallel connection, the current is sum of the individual module. Modules with different electric performance models can not be connected in one string .



The maximum allowed quantity of modules in string connection shall be calculated according to relative ragulations. The open circuit voltage value under the expected lowest temperature shall not exceed the maximum system voltage value allowed by modules and other values required by DC electric parts (maximum system voltage is DC1000V/DC1500V— actually system voltage is designed based on the selected module and inverter model.) The VOC factor can be calculated by the following formula.




$$CVoc=1-\beta Vocx(25-T)$$

T: The expected lowest temperature of the imstallation site,

β ; VOC temperature coefficient (%/C)(refer to modules data sheet for further detail)


if there is reverse current exceeding the maximum fuse current flowing through the module, use overcurrent protection device with the same specifications to protect the module; if the parallel connection are more than 2, there must be an overcurrent protection device on each string of module.

FRAME





SOLAR CELL POSITION

15mm



3 ± 0.5 mm



1.8mm

3 ± 0.5 mm

- f) Follow the requirements of applicable local and national electrical codes.
- g) These modules contain factory installed by pass diode .If these modules are incorrectly connected to each other, the bypass diodes, cable or junction box may be damaged.
- h) The cable of the junction box is defined as L, as showed below in Figure 11. For AE Solar standard module, L is 900/1200mm; and for customized module, L can be based on your condition. Please take the cable length into consideration before designing the wiring layout.



- i) It is recommend to use negatively grounded inverters to avoid the PID effect for non-PID free modules.
- j) If modules are connected in series, the total voltage is equal to the sum of individual voltages. The recommended as below,

$$\text{System voltage} \geq N \cdot V_{oc} [1 + TCV_{oc} \cdot (T_{min} - 25)]$$

Where

N module numbers in series


Voc Open circuit voltage (refer to product label or data sheet)

TCVoc Temperature coefficient of open circuit voltage (refer to product label or data sheet)

Tmin Minimum ambient temperature

4. Maintenance and Care

It is required to perform regular inspection and maintenance of the modules, especially during the warranty period. To ensure optimum module performance, AE Solar recommends the following maintenance measures:



4.1 Visual Inspection

Inspect the modules visually to find if there are any visual defects, If there are, the following items should be evaluated:

- a) If modules are observed having slight cell color differences at different angles, this is a normal phenomenon of modules with anti-reflection coating technology.
- b) Whether the glass is broken.
- c) No sharp objects are in contact with the PV module surfaces.
- d) PV modules are not shaded by unwanted obstacles and; or foreign material.
- e) Corrosion along the cells' bus-bar. The corrosion is caused by moisture intrusion through the module back sheet. Check the back sheet for damage.
- f) Check whether the back sheet is burnt.
- g) Check if screws and mounting brackets are tight, adjust and tighten as necessary.

4.2 Cleaning

- a) A build up of dust or dirt on the module(s) front face will result in a decreased energy output. Clean the panel(s) preferably once per annum if possible (depend on site conditions) using a soft cloth dry or damp, as necessary. Water with high mineral content may leave deposits on the glass surface and is not recommended.
- b) Never use abrasive material under any circumstances.
- c) In order to reduce the potential for electrical and thermal shock, AE Solar recommends cleaning PV modules during early morning or late afternoon hours when solar radiation is low and the modules are cooler, especially in regions with hotter temperatures.
- d) Never attempt to clean a PV module with broken glass or other signs of exposed wiring, as this presents a shock hazard.
- e) Never use chemicals when cleaning modules as this may affect the module warranty and energy output.

4.3 Inspection of Connector and Cable

It's recommended to implement the following preventive maintenance every 6 months:

- a) Check the sealing gels of the junction box for any damage.
- b) Examine the PV module(s) for signs of deterioration. Check all wiring for possible rodent damage, weathering and that all connections are tight and corrosion free. Check electrical leakage to ground.

5. Electrical Specification

The module electrical rating are measured under Standard Test Conditions, which are 1000W/m², irradiance with AM 1.5 spectrum and 25 deg (77F°) ambient temperature. The module might produce more or less voltage or current than rated value in uncertainty condition.

6. Disclaimer of Liability

Because the use of the manual and the conditions or methods of installation, operation, use and maintenance of photovoltaic (PV) product are beyond AE Solar's control, AE Solar does not accept responsibility and expressly disclaims liability for loss ,damage, or expense arising out of or in any way connected with such installation, operation, use or maintenance.

No responsibility is assumed by AE Solar for any infringement of patents or other rights of third parties, which may result from use of the PV product. NO license is granted by implication or otherwise under any patent or patent rights.

The information in this manual is based on AE Solar's knowledge and experience and is believed to be reliable, but such information including product specification (without limitations) and suggestions do not constitute a warranty, expresses or implied. AE Solar reserve the right to change the manual, the PV produce, the specifications, or product information sheets without prior notice.

Electrical Specifications			STC					NMOT				
Module Type		Module type	Maximum Power at STC (Pmax,WP)	Maximum Power Voltage (Vmp,V)	Maximum Power Current (imp,A)	Open Circuit Voltage (Voc,V)	Short Circuit Current (Isc,A)	Maximum Power at STC (Pmax,WP)	Maximum Power Voltage (Vmp,V)	Maximum Power Current (imp,A)	Open Circuit Voltage (Voc,V)	Short Circuit Current (Isc,A)
72 cells	P	AE315P6-72	315	36.66	8.59	45.59	9.24	238	34.13	6.98	37.02	8.14
		AE320P6-72	320	36.75	8.71	45.72	9.28	242	34.22	7.07	37.12	8.25
		AE325P6-72	325	36.83	8.82	45.83	9.33	246	34.29	7.17	37.21	8.36
		AE330P6-72	330	36.97	8.93	45.89	9.37	249	34.42	7.25	37.26	8.47
		AE335P6-72	335	37.05	9.04	45.93	9.41	253	34.49	7.34	37.30	8.60
		AE340P6-72	340	37.09	9.17	45.97	9.44	257	34.53	7.44	37.33	8.72
72 cells	M	AE340M6-72	340	39.09	8.70	46.94	9.48	257	36.39	7.06	38.12	8.54
		AE345M6-72	345	39.34	8.77	47.08	9.51	261	36.63	7.12	38.23	8.64
		AE350M6-72	350	39.46	8.87	47.15	9.55	265	36.74	7.20	38.28	8.75
		AE355M6-72	355	39.51	8.99	47.30	9.58	268	36.79	7.30	38.41	8.85
		AE360M6-72	360	39.55	9.10	47.38	9.62	272	36.82	7.39	38.47	8.95
		AE365M6-72	365	39.58	9.22	47.42	9.65	276	36.85	7.49	38.51	9.07
		AE370M6-72	370	39.63	9.34	47.48	9.69	280	36.90	7.58	38.55	9.18
		AE375M6-72	375	39.66	9.46	47.53	9.75	284	36.91	7.68	38.59	9.30
		AE380M6-72	380	39.71	9.57	47.59	9.82	287	36.97	7.77	38.64	9.41
		AE385M6-72	385	39.73	9.69	47.81	9.95	921	36.99	7.87	38.82	9.49
Maximum system voltage		(V)	1000/1500									
Maximum overcurrent protection rating		(A)	15									
Nominal module operating temperature		(C°)	-40 to +85									
Power tolerance		Pmax(WP)	0/+4.99									
Temp. coefficients of pmax		(% /C°)	-0.38									
Temp. coefficients of Voc		(% /C°)	-0.29									
Temp. coefficients of Isc		(% /C°)	0.05									

Electrical Specifications		STC						NMOT				
Module Type		Module type	Maximum Power at STC (Pmax,WP)	Maximum Power Voltage (Vmp,V)	Maximum Power Current (imp,A)	Open Circuit Voltage (Voc,V)	Short Circuit Current (Isc,A)	Maximum Power at STC (Pmax,WP)	Maximum Power Voltage (Vmp,V)	Maximum Power Current (imp,A)	Open Circuit Voltage (Voc,V)	Short Circuit Current (Isc,A)
60 cells	M	AE HM305M6-60	305	32.80	9.30	40.31	9.83	231	30.53	7.55	32.73	8.92
		AE HM310M6-60	310	33.00	9.40	40.50	9.92	234	30.70	7.63	32.89	9.02
		AE HM315M6-60	315	33.20	9.49	40.70	10.04	238	30.90	7.71	33.05	9.12
		AE HM320M6-60	320	33.40	9.59	40.90	10.15	242	31.07	7.79	33.21	9.22
		AE HM325M6-60	325	33.61	9.68	41.10	10.20	246	31.26	7.86	33.37	9.32
		AE HM330M6-60	330	33.81	9.76	41.31	10.37	249	31.48	7.93	33.54	9.41
		AE HM335M6-60	335	34.02	9.85	41.49	10.49	253	31.67	8.00	33.69	9.52

72 cells	M	AE HM370M6-72	370	39.9	9.28	48.51	9.61	280	37.12	7.54	39.39	8.99
		AE HM375M6-72	375	40.2	9.33	48.72	9.68	284	37.42	7.58	39.56	9.07
		AE HM380M6-72	380	40.5	9.39	48.90	9.75	287	37.68	7.62	39.71	9.16
		AE HM385M6-72	385	40.8	9.44	49.10	9.92	291	37.97	7.67	39.87	9.24
		AE HM390M6-72	390	41.1	9.49	49.30	10.12	295	38.26	7.71	40.03	9.32
		AE HM395M6-72	395	41.40	9.54	49.48	10.54	299	38.55	7.75	40.18	9.41
		AE HM400M6-72	400	41.71	9.59	49.69	10.59	302	38.83	7.79	40.35	9.49
Maximum system voltage		(V)	1000/1500									
Maximum overcurrent protection rating		(A)	15									
Nominal module operating temperature		(C°)	-40 to +85									
Power tolerance		Pmax(WP)	0/+4.99									
Temp. coefficients of pmax		(% /C°)	-0.38									
Temp. coefficients of Voc		(% /C°)	-0.29									
Temp. coefficients of Isc		(% /C°)	0.05									

